

Submittal Data: System 9RLS ASU9RLS & AOU9RLS



Job Name: _____ Location: _____
 Purchaser: _____
 Engineer: _____
 Submitted To: _____ For: Reference Approval Construction
 Submitted By: _____
 Unit Designation: _____ Schedule No. _____ Model No.: _____

Capacities:

Cooling	9,000 BTU/h
Outdoor Design Temp. <i>F° DB/WB</i>	95/75
Heating	12,000 BTU/h
Outdoor Design Temperature <i>F° DB/WB</i>	47/43
HSPF	12
SEER	26.0
EER <i>Cooling/Heating</i>	17.31/15
Voltage/Frequency/Phase	208-230/60/1

Indoor Unit:

Noise Level Cooling <i>db (A) - H/ M/ L/ Q</i>	46/ 41/ 33/ 24
Noise Level Heating <i>db (A) - H/ M/ L/ Q</i>	46/ 41/ 33 /24
Weight	24 lbs.

Outdoor Unit:

Noise Level <i>Cooling/Heating</i>	48/48
Recommended Fuse Size	15A
Min. Ampacity	10A
Running Current <i>Cooling</i>	2.5A
Running Current <i>Heating</i>	3.7A
Weight	88 lbs.

Refrigerant Piping:

Max Ht. Difference	49 ft.
Max Total or Combined Length	66 ft.
Discharge Vapor Line (O.D.)	1/4 in.
Suction (O.D.)	3/8 in.

- ◆ Six year compressor warranty
- ◆ Two year parts warranty
- ◆ Digital wireless remote control
- ◆ 4-way automatic louvers
- ◆ Min Heat (50F heating set point)
- ◆ Built in Low Ambient
- ◆ Auto Restart/ Reset
- ◆ 24 hour timer
- ◆ Optional Wired Remote Control
- ◆ Dry mode
- ◆ Refrigerant R410A
- ◆ Quiet Mode

Notes:

OUTLINE AND DIMENSIONS

